

**ORDINANCE NO. 1160**

AN ORDINANCE OF THE CITY OF SPRINGFIELD, NEBRASKA, AMENDING SPRINGFIELD MUNICIPAL CODE CHAPTER 9 BUILDING REGULATIONS, ARTICLE 2 BUILDING CODE, SECTION 9-201 BUILDING CODE; ADOPTED BY REFERENCE; TO HARMONIZE WITH STATE LAW; TO REPEAL CONFLICTING ORDINANCES AND SECTIONS; AND TO PROVIDE AN EFFECTIVE DATE.

BE IT ORDAINED BY THE MAYOR AND CITY COUNCIL OF THE CITY OF SPRINGFIELD, NEBRASKA:


Section 1. Chapter 9, Article 2, Section 9-201 of the Municipal Code of Springfield, Nebraska is amended to read as follows:

**§9-201 BUILDING CODE; ADOPTED BY REFERENCE.** To provide certain minimum standards, provisions, and requirements for safe and stable design, methods of construction, and uses of materials in buildings hereafter erected, constructed, enlarged, altered, repaired, relocated, and converted, the 2018 International Building Code, as issued by the International Code Council and amended by Exhibit A to Ordinance No. 1153, passed 9/3/2024, and printed in book or pamphlet form, the 2018 International Residential Code, as issued by the International Code Council and amended by Exhibit B to Ordinance No. 1153, passed 9/3/2024, and printed in book or pamphlet form, the 2018 International Mechanical Code, as issued by the International Code Council, the 2018 International Fuel Gas Code, as issued by the International Code Council, the 2018 International Plumbing Code, as issued by the International Code Council, the 2018 International Energy Conservation Code, as issued by the International Code Council, the 2023 National Electric Code with five (5) Temporarily Amended Code Exclusions as shown on Exhibit A to Ordinance No. 1160, passed 10/1/2024, and printed in book or pamphlet form, and the 2009 International ANSI A117.1 Assessable and Useable Buildings and Facilities Code. A copy of said Codes is on file at the office of the Municipal Clerk and is available for public inspection at any reasonable time. The provisions of said Codes shall be controlling throughout the Municipality and throughout its zoning jurisdiction. (Ref. 17-1001, 18-132, 19-902, 19-922 RS Neb.) (Amended by Ord. Nos. 298, 3/1/88; 374, 3/21/95; 594, 1/21/03; 674, 6/21/06; 709, 3/7/06; 796, 10/4/11; 861, 8/5/14; 942, 2/7/17; 1153, 9/3/24)


Section 2. Any other ordinance or code section passed and approved prior to passage, approval, and publication or posting of this ordinance and in conflict with its provisions is repealed.

Section 3. This ordinance shall take effect and be in full force from and after its passage, approval, and publication or posting as required by law.

Passed and approved this 1<sup>st</sup> day of October 2024.

  
Mayor

(SEAL)

  
City Clerk



**EXHIBIT A**  
**2023 National Electric Code Adoption - Temporarily Amended Code Exclusions**

The Nebraska State Legislature has adopted the 2023 NEC and State Enforcement of the 2023 NEC will begin August 1, 2024.

The adoption of the 2023 NEC includes a Temporary Amendment of five (5) specific codes. Those specific amendments will remain AS ENFORCED under the current 2017 NEC and will EXPIRE with the Adoption of the 2026 NEC.

The five (5) temporarily amended 2023 NEC code exclusions are as follows:

1. **210.8(A): Dwelling Units:** All 125-volt through 250-volt receptacles installed in the locations specified in 210.8(A)(1) through (A)(12) and supplied by single-phase branch circuits rated 150 volts or less to ground shall have ground-fault circuit-interrupter protection for personnel.
2. **210.8(A)(3): Outdoors: Exception to (3):** Receptacles that are not readily accessible and are supplied by a branch circuit dedicated to electric snow-melting, deicing, or pipeline and vessel heating equipment shall be permitted to be installed in accordance with 426.28 or 427.22, as applicable.
3. **210.8(A)(5): Basements: Exception to (5):** A receptacle supplying only a permanently installed fire alarm or burglar alarm system shall not be required to have ground-fault circuit-interrupter protection.
4. **230.67(A): Surge-Protective Device:** All services supplying the following occupancies shall be provided with a surge-protective device (SPD):
  - a. Dwelling units
  - b. Dormitory units
  - c. Guest rooms and guest suites of hotels and motels
  - d. Areas of nursing homes and limited-care facilities used exclusively as patient sleeping rooms
5. **230.85: Emergency Disconnects:** For one- and two-family dwelling units, all service conductors shall terminate in disconnecting means having a short-circuit current rating equal to or greater than the available fault current, installed in a readily accessible outdoor location. If more than one disconnect is provided, they shall be grouped. Each disconnect shall be one of the following:
  - a. Service disconnects marked as follows:
    - i. EMERGENCY DISCONNECT, SERVICE DISCONNECT
  - b. Meter disconnects installed per 230.82(3) and marked as follows:
    - i. EMERGENCY DISCONNECT, METER DISCONNECT, NOT SERVICE EQUIPMENT
  - c. Other listed disconnect switches or circuit breakers on the supply side of each service disconnect that are suitable for use as service equipment and marked as follows:
    - i. EMERGENCY DISCONNECT, NOT SERVICE EQUIPMENT
  - d. Markings shall comply with 110.21(B).